

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on October 4,2016)**

Water Level of the accumulated water (at 12:00 on October 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,376 mm (54 mm increase since 12:00 on October 3)	T.P.+ 1,661 mm (5 mm increase since 12:00 on October 3)	T.P.+ 1,627 mm (29 mm increase since 12:00 on October 3)	T.P.+ 1,738 mm (1 mm decrease since 12:00 on October 3)
	Water level of Reactor Building	T.P.+ 1,493 mm (56 mm increase since 12:00 on October 3)	T.P.+ 1,788 mm (4 mm decrease since 12:00 on October 3)	T.P.+ 1,673 mm (32 mm increase since 12:00 on October 3)	T.P.+ 1,525 mm (9 mm increase since 12:00 on October 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,349 mm (136 mm decrease since 12:00 on October 3) T.P.+ 530 mm (93 mm decrease since 12:00 on October 3) T.P.+ 2,931 mm (5 mm increase since 12:00 on October 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.