

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 12:00 on October 5,2016)**

Water Level of the accumulated water (at 12:00 on October 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,431 mm (55 mm increase since 12:00 on October 4)	T.P.+ 1,681 mm (20 mm increase since 12:00 on October 4)	T.P.+ 1,543 mm (84 mm decrease since 12:00 on October 4)	T.P.+ 1,740 mm (2 mm increase since 12:00 on October 4)
	Water level of Reactor Building	T.P.+ 1,540 mm (47 mm increase since 12:00 on October 4)	T.P.+ 1,788 mm (No change since 12:00 on October 4)	T.P.+ 1,620 mm (53 mm decrease since 12:00 on October 4)	T.P.+ 1,531 mm (6 mm increase since 12:00 on October 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3,627 mm (278 mm increase since 12:00 on October 4) T.P.+ 0 mm (530 mm decrease since 12:00 on October 4) T.P.+ 2,938 mm (7 mm increase since 12:00 on October 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.