

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 2,)**

Water Level of the accumulated water (at 0:00 on March 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,050 mm (10 mm increase since 0:00 on March 1)	T.P.+ 1,131 mm (7 mm decrease since 0:00 on March 1)	T.P.+ 952 mm (20 mm increase since 0:00 on March 1)	T.P.+ 1,098 mm (1 mm decrease since 0:00 on March 1)
	Water level of Reactor Building	T.P.+ 1,130 mm (10 mm increase since 0:00 on March 1)	T.P.+ 1,147 mm (14 mm decrease since 0:00 on March 1)	T.P.+ 935 mm (22 mm increase since 0:00 on March 1)	T.P.+ 980 mm (4 mm decrease since 0:00 on March 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,337 mm (156 mm increase since 0:00 on March 1)  T.P.+ 994 mm ( 1 mm increase since 0:00 on March 1)  T.P.+ 2,761 mm (8 mm increase since 0:00 on March 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.