

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 4,)**

Water Level of the accumulated water (at 0:00 on March 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,068 mm (8 mm increase since 0:00 on March 3)	T.P.+ 1,129 mm (1 mm increase since 0:00 on March 3)	T.P.+ 988 mm (17 mm increase since 0:00 on March 3)	T.P.+ 1,099 mm (1 mm increase since 0:00 on March 3)
	Water level of Reactor Building	T.P.+ 1,110 mm (1 mm decrease since 0:00 on March 3)	T.P.+ 1,164 mm (19 mm increase since 0:00 on March 3)	T.P.+ 967 mm (14 mm increase since 0:00 on March 3)	T.P.+ 977 mm (No change since 0:00 on March 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,477 mm (22 mm increase since 0:00 on March 3) T.P.+ 1,063 mm (69 mm increase since 0:00 on March 3) T.P.+ 2,777 mm (10 mm increase since 0:00 on March 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.