

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 6,)**

| Water Level of the accumulated water (at 0:00 on March 6) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|---|--|---|---|--|---|
| | Water level of Turbine Building | T.P.+ 1,012 mm (63 mm decrease since 0:00 on March 5) | T.P.+ 1,129 mm (1 mm increase since 0:00 on March 5) | T.P.+ 985 mm (17 mm increase since 0:00 on March 5) | T.P.+ 1,098 mm (1 mm decrease since 0:00 on March 5) |
| | Water level of Reactor Building | T.P.+ 1,132 mm (6 mm increase since 0:00 on March 5) | T.P.+ 1,155 mm (14 mm decrease since 0:00 on March 5) | T.P.+ 967 mm (18 mm increase since 0:00 on March 5) | T.P.+ 976 mm (No change since 0:00 on March 5) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ 2,478 mm (2 mm increase since 0:00 on March 5) T.P.+ 1,050 mm (181 mm decrease since 0:00 on March 5) T.P.+ 2,786 mm (4 mm increase since 0:00 on March 5) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.