

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 7,)**

Water Level of the accumulated water (at 0:00 on March 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,020 mm (8 mm increase since 0:00 on March 6)	T.P.+ 1,131 mm (2 mm increase since 0:00 on March 6)	T.P.+ 970 mm (15 mm decrease since 0:00 on March 6)	T.P.+ 1,101 mm (3 mm increase since 0:00 on March 6)
	Water level of Reactor Building	T.P.+ 1,177 mm (45 mm increase since 0:00 on March 6)	T.P.+ 1,155 mm (No change since 0:00 on March 6)	T.P.+ 958 mm (9 mm decrease since 0:00 on March 6)	T.P.+ 976 mm (No change since 0:00 on March 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,480 mm (2 mm increase since 0:00 on March 6)  T.P.+ 984 mm ( 66 mm decrease since 0:00 on March 6)  T.P.+ 2,791 mm (5 mm increase since 0:00 on March 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.