

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 10,)**

Water Level of the accumulated water (at 0:00 on March 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,034 mm (3 mm increase since 0:00 on March 9)	T.P.+ 1,126 mm (5 mm decrease since 0:00 on March 9)	T.P.+ 992 mm (14 mm increase since 0:00 on March 9)	T.P.+ 1,095 mm (2 mm increase since 0:00 on March 9)
	Water level of Reactor Building	T.P.+ 1,134 mm (10 mm increase since 0:00 on March 9)	T.P.+ 1,150 mm (18 mm decrease since 0:00 on March 9)	T.P.+ 976 mm (16 mm increase since 0:00 on March 9)	T.P.+ 967 mm (No change since 0:00 on March 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 2,481 mm (1 mm increase since 0:00 on March 9)  T.P.+ 653 mm ( 80 mm decrease since 0:00 on March 9)  T.P.+ 2,809 mm (6 mm increase since 0:00 on March 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.