

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 21,)**

Water Level of the accumulated water (at 0:00 on March 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 1,000 mm (8 mm increase since 0:00 on March 20)	T.P.+ 1,121 mm (No change since 0:00 on March 20)	T.P.+ 916 mm (4 mm increase since 0:00 on March 20)	T.P.+ 1,086 mm (3 mm decrease since 0:00 on March 20)
	Water level of Reactor Building	T.P.+ 1,126 mm (9 mm increase since 0:00 on March 20)	T.P.+ 1,150 mm (5 mm increase since 0:00 on March 20)	T.P.+ 907 mm (4 mm decrease since 0:00 on March 20)	T.P.+ 956 mm (3 mm decrease since 0:00 on March 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,616 mm (No change since 0:00 on March 20) T.P.+ 300 mm (147 mm decrease since 0:00 on March 20) T.P.+ 2,896 mm (9 mm increase since 0:00 on March 20)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.