

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on March 31,)**

Water Level of the accumulated water (at 0:00 on March 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	T.P.+ 645 mm (1 mm increase since 0:00 on March 30)	T.P.+ 1,122 mm (1 mm decrease since 0:00 on March 30)	T.P.+ 977 mm (17 mm increase since 0:00 on March 30)	T.P.+ 1,089 mm (2 mm increase since 0:00 on March 30)
	Water level of Reactor Building	T.P.+ 1,126 mm (1 mm increase since 0:00 on March 30)	T.P.+ 1,155 mm (6 mm decrease since 0:00 on March 30)	T.P.+ 967 mm (19 mm increase since 0:00 on March 30)	T.P.+ 955 mm (2 mm increase since 0:00 on March 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,747 mm (1 mm increase since 0:00 on March 30) T.P.+ 327 mm (26 mm increase since 0:00 on March 30) T.P.+ 2,976 mm (5 mm increase since 0:00 on March 30)		
Notes					

For quick publication of the data of water level, values are provided as reference values.