

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on April 3,)**

Water Level of the accumulated water (at 0:00 on April 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,122 mm (No change since 0:00 on April 2)	T.P.+ 946 mm (18 mm increase since 0:00 on April 2)	T.P.+ 1,084 mm (1 mm increase since 0:00 on April 2)
	Water level of Reactor Building	T.P.+ 1,111 mm (17 mm decrease since 0:00 on April 2)	T.P.+ 1,159 mm (9 mm increase since 0:00 on April 2)	T.P.+ 935 mm (17 mm increase since 0:00 on April 2)	T.P.+ 950 mm (No change since 0:00 on April 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,751 mm (2 mm increase since 0:00 on April 2) T.P.+ 100 mm ( 233 mm decrease since 0:00 on April 2) T.P.+ 3,002 mm (7 mm increase since 0:00 on April 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.