

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on April 4,)**

Water Level of the accumulated water (at 0:00 on April 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,129 mm (7 mm increase since 0:00 on April 3)	T.P.+ 961 mm (15 mm increase since 0:00 on April 3)	T.P.+ 1,085 mm (1 mm increase since 0:00 on April 3)
	Water level of Reactor Building	T.P.+ 1,146 mm (35 mm increase since 0:00 on April 3)	T.P.+ 1,143 mm (16 mm decrease since 0:00 on April 3)	T.P.+ 951 mm (16 mm increase since 0:00 on April 3)	T.P.+ 950 mm (No change since 0:00 on April 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 2,771 mm (20 mm increase since 0:00 on April 3) T.P.+ -198 mm (298 mm decrease since 0:00 on April 3) T.P.+ 3,009 mm (7 mm increase since 0:00 on April 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.