

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on April 5,)**

| Water Level of the accumulated water (at 0:00 on April 5) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|---|---|---|
| | Water level of Turbine Building | - Removal completed on March, 2017 | T.P.+ 1,128 mm (1 mm decrease since 0:00 on April 4) | T.P.+ 957 mm (4 mm decrease since 0:00 on April 4) | T.P.+ 1,086 mm (1 mm increase since 0:00 on April 4) |
| | Water level of Reactor Building | T.P.+ 1,149 mm (3 mm increase since 0:00 on April 4) | T.P.+ 1,164 mm (21 mm increase since 0:00 on April 4) | T.P.+ 955 mm (4 mm increase since 0:00 on April 4) | T.P.+ 950 mm (No change since 0:00 on April 4) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ 2,799 mm (28 mm increase since 0:00 on April 4) T.P.+ -373 mm (175 mm decrease since 0:00 on April 4) T.P.+ 3,016 mm (7 mm increase since 0:00 on April 4) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.