

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on May 4,)**

Water Level of the accumulated water (at 0:00 on May 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,124 mm (1 mm decrease since 0:00 on May 3)	T.P.+ 945 mm (No change since 0:00 on May 3)	T.P.+ 1,093 mm (No change since 0:00 on May 3)
	Water level of Reactor Building	T.P.+ 1,146 mm (4 mm decrease since 0:00 on May 3)	T.P.+ 1,161 mm (16 mm increase since 0:00 on May 3)	T.P.+ 933 mm (10 mm decrease since 0:00 on May 3)	T.P.+ 951 mm (2 mm decrease since 0:00 on May 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,060 mm (55 mm decrease since 0:00 on May 3) T.P.+ -106 mm ( 4 mm increase since 0:00 on May 3) T.P.+ 2,893 mm (7 mm increase since 0:00 on May 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.