

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on May 5,)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 0:00 on May 5)	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,122 mm (2 mm decrease since 0:00 on May 4)	T.P.+ 960 mm (15 mm increase since 0:00 on May 4)	T.P.+ 1,093 mm (No change since 0:00 on May 4)
	Water level of Reactor Building	T.P.+ 1,143 mm (3 mm decrease since 0:00 on May 4)	T.P.+ 1,143 mm (18 mm decrease since 0:00 on May 4)	T.P.+ 948 mm (15 mm increase since 0:00 on May 4)	T.P.+ 952 mm (1 mm increase since 0:00 on May 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 968 mm (92 mm decrease since 0:00 on May 4) T.P.+ -102 mm (4 mm increase since 0:00 on May 4) T.P.+ 2,900 mm (7 mm increase since 0:00 on May 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.