

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 2,)**

Water Level of the accumulated water (at 0:00 on June 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,118 mm (1 mm increase since 0:00 on June 1)	T.P.+ 1,023 mm (22 mm increase since 0:00 on June 1)	T.P.+ 1,076 mm (4 mm increase since 0:00 on June 1)
	Water level of Reactor Building	T.P.+ 1,157 mm (7 mm increase since 0:00 on June 1)	T.P.+ 1,143 mm (21 mm decrease since 0:00 on June 1)	T.P.+ 1,011 mm (22 mm increase since 0:00 on June 1)	T.P.+ 959 mm (1 mm increase since 0:00 on June 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,020 mm (62 mm decrease since 0:00 on June 1) T.P.+ 109 mm ( 6 mm increase since 0:00 on June 1) T.P.+ 2,860 mm (17 mm increase since 0:00 on June 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.