

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 3,)**

Water Level of the accumulated water (at 0:00 on June 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,119 mm (1 mm increase since 0:00 on June 2)	T.P.+ 1,025 mm (2 mm increase since 0:00 on June 2)	T.P.+ 1,080 mm (4 mm increase since 0:00 on June 2)
	Water level of Reactor Building	T.P.+ 1,140 mm (17 mm decrease since 0:00 on June 2)	T.P.+ 1,168 mm (25 mm increase since 0:00 on June 2)	T.P.+ 1,024 mm (13 mm increase since 0:00 on June 2)	T.P.+ 959 mm (No change since 0:00 on June 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,005 mm (15 mm decrease since 0:00 on June 2) T.P.+ 115 mm (6 mm increase since 0:00 on June 2) T.P.+ 2,882 mm (22 mm increase since 0:00 on June 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.