

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 5,)**

Water Level of the accumulated water (at 0:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,120 mm (1 mm increase since 0:00 on June 4)	T.P.+ 966 mm (1 mm increase since 0:00 on June 4)	T.P.+ 1,077 mm (3 mm increase since 0:00 on June 4)
	Water level of Reactor Building	T.P.+ 1,149 mm (1 mm decrease since 0:00 on June 4)	T.P.+ 1,157 mm (18 mm decrease since 0:00 on June 4)	T.P.+ 954 mm (12 mm decrease since 0:00 on June 4)	T.P.+ 959 mm (1 mm decrease since 0:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 1,025 mm (52 mm decrease since 0:00 on June 4) T.P.+ 124 mm (5 mm increase since 0:00 on June 4) T.P.+ 2,914 mm (16 mm increase since 0:00 on June 4)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.