

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 7,)**

| | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|---|---|--|
| Water Level of the accumulated water (at 0:00 on June 7) | Water level of Turbine Building | - Removal completed on March, 2017 | T.P.+ 1,107 mm (8 mm decrease since 0:00 on June 6) | T.P.+ 946 mm (11 mm decrease since 0:00 on June 6) | T.P.+ 1,071 mm (7 mm decrease since 0:00 on June 6) |
| | Water level of Reactor Building | T.P.+ 1,117 mm (10 mm decrease since 0:00 on June 6) | T.P.+ 1,155 mm (4 mm decrease since 0:00 on June 6) | T.P.+ 931 mm (23 mm decrease since 0:00 on June 6) | T.P.+ 955 mm (4 mm decrease since 0:00 on June 6) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ 995 mm (No change since 0:00 on June 6) T.P.+ 134 mm (5 mm increase since 0:00 on June 6) T.P.+ 2,947 mm (17 mm increase since 0:00 on June 6) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.