

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 8,)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 0:00 on June 8)	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,111 mm (4 mm increase since 0:00 on June 7)	T.P.+ 962 mm (16 mm increase since 0:00 on June 7)	T.P.+ 1,074 mm (3 mm increase since 0:00 on June 7)
	Water level of Reactor Building	T.P.+ 1,123 mm (6 mm increase since 0:00 on June 7)	T.P.+ 1,129 mm (26 mm decrease since 0:00 on June 7)	T.P.+ 948 mm (17 mm increase since 0:00 on June 7)	T.P.+ 955 mm (No change since 0:00 on June 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 908 mm (87 mm decrease since 0:00 on June 7)  T.P.+ 140 mm ( 6 mm increase since 0:00 on June 7)  T.P.+ 2,960 mm (13 mm increase since 0:00 on June 7)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.