

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 9,)**

Water Level of the accumulated water (at 0:00 on June 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,110 mm (1 mm decrease since 0:00 on June 8)	T.P.+ 978 mm (16 mm increase since 0:00 on June 8)	T.P.+ 1,076 mm (2 mm increase since 0:00 on June 8)
	Water level of Reactor Building	T.P.+ 1,116 mm (7 mm decrease since 0:00 on June 8)	T.P.+ 1,147 mm (18 mm increase since 0:00 on June 8)	T.P.+ 962 mm (14 mm increase since 0:00 on June 8)	T.P.+ 955 mm (No change since 0:00 on June 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 828 mm (80 mm decrease since 0:00 on June 8) T.P.+ 144 mm (4 mm increase since 0:00 on June 8) T.P.+ 2,975 mm (15 mm increase since 0:00 on June 8)		
Notes					

For quick publication of the data of water level, values are provided as reference values.