

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 10,)**

Water Level of the accumulated water (at 0:00 on June 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,115 mm (5 mm increase since 0:00 on June 9)	T.P.+ 990 mm (12 mm increase since 0:00 on June 9)	T.P.+ 1,078 mm (2 mm increase since 0:00 on June 9)
	Water level of Reactor Building	T.P.+ 1,127 mm (11 mm increase since 0:00 on June 9)	T.P.+ 1,157 mm (10 mm increase since 0:00 on June 9)	T.P.+ 978 mm (16 mm increase since 0:00 on June 9)	T.P.+ 956 mm (1 mm increase since 0:00 on June 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building  High Temperature Incinerator Building  On-site Bunker Building	T.P.+ 743 mm (85 mm decrease since 0:00 on June 9)  T.P.+ 149 mm ( 5 mm increase since 0:00 on June 9)  T.P.+ 2,991 mm (16 mm increase since 0:00 on June 9)		
Notes					

For quick publication of the data of water level, values are provided as reference values.