

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on June 15,)**

Water Level of the accumulated water (at 0:00 on June 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,112 mm (2 mm increase since 0:00 on June 14)	T.P.+ 1,014 mm (11 mm increase since 0:00 on June 14)	T.P.+ 1,080 mm (4 mm increase since 0:00 on June 14)
	Water level of Reactor Building	T.P.+ 1,121 mm (1 mm decrease since 0:00 on June 14)	T.P.+ 1,164 mm (21 mm increase since 0:00 on June 14)	T.P.+ 1,004 mm (14 mm increase since 0:00 on June 14)	T.P.+ 954 mm (No change since 0:00 on June 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 516 mm (65 mm decrease since 0:00 on June 14) T.P.+ 174 mm (6 mm increase since 0:00 on June 14) T.P.+ 2,771 mm (11 mm increase since 0:00 on June 14)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.