

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 4,)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 0:00 on July 4)	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,107 mm (1 mm increase since 0:00 on July 3)	T.P.+ 919 mm (20 mm increase since 0:00 on July 3)	T.P.+ 1,059 mm (2 mm increase since 0:00 on July 3)
	Water level of Reactor Building	T.P.+ 1,116 mm (6 mm increase since 0:00 on July 3)	T.P.+ 1,159 mm (33 mm increase since 0:00 on July 3)	T.P.+ 947 mm (21 mm increase since 0:00 on July 3)	T.P.+ 940 mm (4 mm increase since 0:00 on July 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -3 mm (24 mm increase since 0:00 on July 3) T.P.+ 325 mm (3 mm increase since 0:00 on July 3) T.P.+ 2,737 mm (9 mm increase since 0:00 on July 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.