

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 8,)**

Water Level of the accumulated water (at 0:00 on July 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,105 mm (15 mm decrease since 0:00 on July 7)	T.P.+ 956 mm (8 mm decrease since 0:00 on July 7)	T.P.+ 1,072 mm (3 mm increase since 0:00 on July 7)
	Water level of Reactor Building	T.P.+ 1,016 mm (98 mm decrease since 0:00 on July 7)	T.P.+ 1,147 mm (15 mm decrease since 0:00 on July 7)	T.P.+ 992 mm (2 mm increase since 0:00 on July 7)	T.P.+ 939 mm (1 mm increase since 0:00 on July 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -48 mm (45 mm decrease since 0:00 on July 7) T.P.+ 352 mm (6 mm increase since 0:00 on July 7) T.P.+ 2,779 mm (11 mm increase since 0:00 on July 7)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.