

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 9,)**

Water Level of the accumulated water (at 0:00 on July 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 1,098 mm (7 mm decrease since 0:00 on July 8)	T.P.+ 930 mm (26 mm decrease since 0:00 on July 8)	T.P.+ 1,057 mm (15 mm decrease since 0:00 on July 8)
	Water level of Reactor Building	T.P.+ 1,025 mm (9 mm increase since 0:00 on July 8)	T.P.+ 1,161 mm (14 mm increase since 0:00 on July 8)	T.P.+ 955 mm (37 mm decrease since 0:00 on July 8)	T.P.+ 935 mm (4 mm decrease since 0:00 on July 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 3 mm (51 mm increase since 0:00 on July 8) T.P.+ 357 mm (5 mm increase since 0:00 on July 8) T.P.+ 2,786 mm (7 mm increase since 0:00 on July 8)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.