

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 16,)**

Water Level of the accumulated water (at 0:00 on July 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 995 mm (2 mm decrease since 0:00 on July 15)	T.P.+ 855 mm (25 mm decrease since 0:00 on July 15)	T.P.+ 1,003 mm (3 mm increase since 0:00 on July 15)
	Water level of Reactor Building	T.P.+ 1,020 mm (6 mm increase since 0:00 on July 15)	T.P.+ 1,047 mm (14 mm increase since 0:00 on July 15)	T.P.+ 882 mm (37 mm decrease since 0:00 on July 15)	T.P.+ 886 mm (1 mm increase since 0:00 on July 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 557 mm (8 mm increase since 0:00 on July 15) T.P.+ 429 mm ( 6 mm increase since 0:00 on July 15) T.P.+ 2,842 mm (8 mm increase since 0:00 on July 15)		
Notes					

For quick publication of the data of water level, values are provided as reference values.