

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 20,)**

Water Level of the accumulated water (at 0:00 on July 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 898 mm (11 mm increase since 0:00 on July 19)	T.P.+ 821 mm (12 mm increase since 0:00 on July 19)	T.P.+ 980 mm (5 mm increase since 0:00 on July 19)
	Water level of Reactor Building	T.P.+ 1,017 mm (5 mm increase since 0:00 on July 19)	T.P.+ 980 mm (14 mm decrease since 0:00 on July 19)	T.P.+ 845 mm (4 mm decrease since 0:00 on July 19)	T.P.+ 865 mm (4 mm increase since 0:00 on July 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 710 mm (54 mm decrease since 0:00 on July 19) T.P.+ 463 mm (19 mm increase since 0:00 on July 19) T.P.+ 2,887 mm (12 mm increase since 0:00 on July 19)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.