

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on July 28,)**

Water Level of the accumulated water (at 0:00 on July 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 977 mm (32 mm increase since 0:00 on July 27)	T.P.+ 865 mm (16 mm increase since 0:00 on July 27)	T.P.+ 974 mm (4 mm increase since 0:00 on July 27)
	Water level of Reactor Building	T.P.+ 925 mm (101 mm decrease since 0:00 on July 27)	T.P.+ 1,049 mm (30 mm increase since 0:00 on July 27)	T.P.+ 892 mm (15 mm increase since 0:00 on July 27)	T.P.+ 855 mm (No change since 0:00 on July 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 186 mm (88 mm decrease since 0:00 on July 27) T.P.+ 507 mm (35 mm increase since 0:00 on July 27) T.P.+ 2,951 mm (9 mm increase since 0:00 on July 27)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.