

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 2,)**

Water Level of the accumulated water (at 0:00 on August 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 996 mm (No change since 0:00 on August 1)	T.P.+ 780 mm (55 mm decrease since 0:00 on August 1)	T.P.+ 906 mm (47 mm decrease since 0:00 on August 1)
	Water level of Reactor Building	T.P.+ 912 mm (7 mm decrease since 0:00 on August 1)	T.P.+ 1,031 mm (14 mm decrease since 0:00 on August 1)	T.P.+ 821 mm (52 mm decrease since 0:00 on August 1)	T.P.+ 810 mm (36 mm decrease since 0:00 on August 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 298 mm (155 mm increase since 0:00 on August 1) T.P.+ 533 mm (5 mm increase since 0:00 on August 1) T.P.+ 2,735 mm (7 mm increase since 0:00 on August 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.