

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 3,)**

Water Level of the accumulated water (at 0:00 on August 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 927 mm (69 mm decrease since 0:00 on August 2)	T.P.+ 771 mm (9 mm decrease since 0:00 on August 2)	T.P.+ 908 mm (2 mm increase since 0:00 on August 2)
	Water level of Reactor Building	T.P.+ 927 mm (15 mm increase since 0:00 on August 2)	T.P.+ 1,033 mm (2 mm increase since 0:00 on August 2)	T.P.+ 796 mm (25 mm decrease since 0:00 on August 2)	T.P.+ 805 mm (5 mm decrease since 0:00 on August 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 392 mm (94 mm increase since 0:00 on August 2) T.P.+ 540 mm (7 mm increase since 0:00 on August 2) T.P.+ 2,743 mm (8 mm increase since 0:00 on August 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.