

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 4,)**

Water Level of the accumulated water (at 0:00 on August 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 900 mm (27 mm decrease since 0:00 on August 3)	T.P.+ 789 mm (18 mm increase since 0:00 on August 3)	T.P.+ 912 mm (4 mm increase since 0:00 on August 3)
	Water level of Reactor Building	T.P.+ 927 mm (No change since 0:00 on August 3)	T.P.+ 956 mm (77 mm decrease since 0:00 on August 3)	T.P.+ 817 mm (21 mm increase since 0:00 on August 3)	T.P.+ 810 mm (5 mm increase since 0:00 on August 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 384 mm (8 mm decrease since 0:00 on August 3) T.P.+ 546 mm (6 mm increase since 0:00 on August 3) T.P.+ 2,749 mm (6 mm increase since 0:00 on August 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.