

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 6,)**

Water Level of the accumulated water (at 0:00 on August 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 897 mm (4 mm decrease since 0:00 on August 5)	T.P.+ 773 mm (8 mm decrease since 0:00 on August 5)	T.P.+ 911 mm (5 mm increase since 0:00 on August 5)
	Water level of Reactor Building	T.P.+ 909 mm (19 mm decrease since 0:00 on August 5)	T.P.+ 940 mm (11 mm decrease since 0:00 on August 5)	T.P.+ 800 mm (8 mm decrease since 0:00 on August 5)	T.P.+ 810 mm (5 mm increase since 0:00 on August 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 334 mm (30 mm decrease since 0:00 on August 5) T.P.+ 555 mm (5 mm increase since 0:00 on August 5) T.P.+ 2,763 mm (7 mm increase since 0:00 on August 5)		
Notes					

For quick publication of the data of water level, values are provided as reference values.