

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 7,)**

Water Level of the accumulated water (at 0:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 896 mm (1 mm decrease since 0:00 on August 6)	T.P.+ 788 mm (15 mm increase since 0:00 on August 6)	T.P.+ 912 mm (1 mm increase since 0:00 on August 6)
	Water level of Reactor Building	T.P.+ 926 mm (17 mm increase since 0:00 on August 6)	T.P.+ 931 mm (9 mm decrease since 0:00 on August 6)	T.P.+ 817 mm (17 mm increase since 0:00 on August 6)	T.P.+ 809 mm (1 mm decrease since 0:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 240 mm (94 mm decrease since 0:00 on August 6) T.P.+ 561 mm (6 mm increase since 0:00 on August 6) T.P.+ 2,770 mm (7 mm increase since 0:00 on August 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.