

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 9,)**

Water Level of the accumulated water (at 0:00 on August 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 906 mm (8 mm increase since 0:00 on August 8)	T.P.+ 809 mm (36 mm increase since 0:00 on August 8)	T.P.+ 909 mm (6 mm increase since 0:00 on August 8)
	Water level of Reactor Building	T.P.+ 932 mm (16 mm increase since 0:00 on August 8)	T.P.+ 970 mm (46 mm increase since 0:00 on August 8)	T.P.+ 838 mm (37 mm increase since 0:00 on August 8)	T.P.+ 805 mm (3 mm increase since 0:00 on August 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 160 mm (78 mm decrease since 0:00 on August 8) T.P.+ 572 mm (6 mm increase since 0:00 on August 8) T.P.+ 2,785 mm (8 mm increase since 0:00 on August 8)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.