

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 11,)**

Water Level of the accumulated water (at 0:00 on August 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 911 mm (1 mm increase since 0:00 on August 10)	T.P.+ 790 mm (11 mm decrease since 0:00 on August 10)	T.P.+ 909 mm (3 mm decrease since 0:00 on August 10)
	Water level of Reactor Building	T.P.+ 953 mm (11 mm increase since 0:00 on August 10)	T.P.+ 966 mm (7 mm increase since 0:00 on August 10)	T.P.+ 817 mm (25 mm decrease since 0:00 on August 10)	T.P.+ 803 mm (2 mm decrease since 0:00 on August 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 83 mm (24 mm decrease since 0:00 on August 10) T.P.+ 610 mm (33 mm increase since 0:00 on August 10) T.P.+ 2,801 mm (7 mm increase since 0:00 on August 10)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.