

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on August 21,)**

Water Level of the accumulated water (at 0:00 on August 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 831 mm (57 mm decrease since 0:00 on August 20)	T.P.+ 725 mm (58 mm decrease since 0:00 on August 20)	T.P.+ 901 mm (8 mm decrease since 0:00 on August 20)
	Water level of Reactor Building	T.P.+ 943 mm (5 mm decrease since 0:00 on August 20)	T.P.+ 937 mm (33 mm decrease since 0:00 on August 20)	T.P.+ 768 mm (58 mm decrease since 0:00 on August 20)	T.P.+ 795 mm (1 mm decrease since 0:00 on August 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -55 mm (339 mm increase since 0:00 on August 20) T.P.+ 618 mm (1 mm decrease since 0:00 on August 20) T.P.+ 2,898 mm (14 mm increase since 0:00 on August 20)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.