

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 2,)**

Water Level of the accumulated water (at 0:00 on September 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 915 mm (2 mm increase since 0:00 on September 1)	T.P.+ 771 mm (4 mm decrease since 0:00 on September 1)	T.P.+ 902 mm (9 mm decrease since 0:00 on September 1)
	Water level of Reactor Building	T.P.+ 942 mm (10 mm decrease since 0:00 on September 1)	T.P.+ 956 mm (23 mm increase since 0:00 on September 1)	T.P.+ 800 mm (10 mm decrease since 0:00 on September 1)	T.P.+ 784 mm (No change since 0:00 on September 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 846 mm (56 mm increase since 0:00 on September 1) T.P.+ 650 mm (1 mm increase since 0:00 on September 1) T.P.+ 2,785 mm (11 mm increase since 0:00 on September 1)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.