

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 3,)**

Water Level of the accumulated water (at 0:00 on September 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 913 mm (2 mm decrease since 0:00 on September 2)	T.P.+ 785 mm (14 mm increase since 0:00 on September 2)	T.P.+ 905 mm (3 mm increase since 0:00 on September 2)
	Water level of Reactor Building	T.P.+ 946 mm (4 mm increase since 0:00 on September 2)	T.P.+ 951 mm (5 mm decrease since 0:00 on September 2)	T.P.+ 817 mm (17 mm increase since 0:00 on September 2)	T.P.+ 784 mm (No change since 0:00 on September 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 798 mm (48 mm decrease since 0:00 on September 2) T.P.+ 649 mm (1 mm decrease since 0:00 on September 2) T.P.+ 2,796 mm (11 mm increase since 0:00 on September 2)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.