

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 4,)**

Water Level of the accumulated water (at 0:00 on September 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 910 mm (3 mm decrease since 0:00 on September 3)	T.P.+ 758 mm (27 mm decrease since 0:00 on September 3)	T.P.+ 892 mm (13 mm decrease since 0:00 on September 3)
	Water level of Reactor Building	T.P.+ 944 mm (2 mm decrease since 0:00 on September 3)	T.P.+ 956 mm (5 mm increase since 0:00 on September 3)	T.P.+ 789 mm (28 mm decrease since 0:00 on September 3)	T.P.+ 782 mm (2 mm decrease since 0:00 on September 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 810 mm (12 mm increase since 0:00 on September 3) T.P.+ 649 mm ( No change since 0:00 on September 3) T.P.+ 2,807 mm (11 mm increase since 0:00 on September 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.