

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 5,)**

| Water Level of the accumulated water (at 0:00 on September 5) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
|--|--|---|--|--|---|
| | Water level of Turbine Building | - Removal completed on March, 2017 | T.P.+ 912 mm (2 mm increase since 0:00 on September 4) | T.P.+ 768 mm (10 mm increase since 0:00 on September 4) | T.P.+ 892 mm (No change since 0:00 on September 4) |
| | Water level of Reactor Building | T.P.+ 949 mm (5 mm increase since 0:00 on September 4) | T.P.+ 972 mm (16 mm increase since 0:00 on September 4) | T.P.+ 798 mm (9 mm increase since 0:00 on September 4) | T.P.+ 782 mm (No change since 0:00 on September 4) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | T.P.+ 736 mm (74 mm decrease since 0:00 on September 4) T.P.+ 661 mm (12 mm increase since 0:00 on September 4) T.P.+ 2,819 mm (12 mm increase since 0:00 on September 4) | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.