

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 6,)**

Water Level of the accumulated water (at 0:00 on September 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 911 mm (1 mm decrease since 0:00 on September 5)	T.P.+ 776 mm (8 mm increase since 0:00 on September 5)	T.P.+ 897 mm (5 mm increase since 0:00 on September 5)
	Water level of Reactor Building	T.P.+ 949 mm (No change since 0:00 on September 5)	T.P.+ 970 mm (2 mm decrease since 0:00 on September 5)	T.P.+ 807 mm (9 mm increase since 0:00 on September 5)	T.P.+ 779 mm (3 mm decrease since 0:00 on September 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 679 mm (57 mm decrease since 0:00 on September 5) T.P.+ 661 mm (No change since 0:00 on September 5) T.P.+ 2,831 mm (12 mm increase since 0:00 on September 5)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.