

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 7,)**

Water Level of the accumulated water (at 0:00 on September 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 911 mm (No change since 0:00 on September 6)	T.P.+ 755 mm (21 mm decrease since 0:00 on September 6)	T.P.+ 901 mm (4 mm increase since 0:00 on September 6)
	Water level of Reactor Building	T.P.+ 944 mm (5 mm decrease since 0:00 on September 6)	T.P.+ 972 mm (2 mm increase since 0:00 on September 6)	T.P.+ 802 mm (5 mm decrease since 0:00 on September 6)	T.P.+ 780 mm (1 mm increase since 0:00 on September 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 655 mm (24 mm decrease since 0:00 on September 6) T.P.+ 662 mm (1 mm increase since 0:00 on September 6) T.P.+ 2,844 mm (13 mm increase since 0:00 on September 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.