

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 8,)**

Water Level of the accumulated water (at 0:00 on September 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 912 mm (1 mm increase since 0:00 on September 7)	T.P.+ 750 mm (5 mm decrease since 0:00 on September 7)	T.P.+ 908 mm (7 mm increase since 0:00 on September 7)
	Water level of Reactor Building	T.P.+ 926 mm (18 mm decrease since 0:00 on September 7)	T.P.+ 935 mm (37 mm decrease since 0:00 on September 7)	T.P.+ 781 mm (21 mm decrease since 0:00 on September 7)	T.P.+ 779 mm (1 mm decrease since 0:00 on September 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 625 mm (30 mm decrease since 0:00 on September 7) T.P.+ 662 mm (No change since 0:00 on September 7) T.P.+ 2,861 mm (17 mm increase since 0:00 on September 7)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.