

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 10,)**

Water Level of the accumulated water (at 0:00 on September 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 908 mm (4 mm decrease since 0:00 on September 9)	T.P.+ 781 mm (13 mm increase since 0:00 on September 9)	T.P.+ 913 mm (2 mm increase since 0:00 on September 9)
	Water level of Reactor Building	T.P.+ 937 mm (No change since 0:00 on September 9)	T.P.+ 968 mm (35 mm increase since 0:00 on September 9)	T.P.+ 810 mm (14 mm increase since 0:00 on September 9)	T.P.+ 779 mm (No change since 0:00 on September 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 460 mm (78 mm decrease since 0:00 on September 9) T.P.+ 663 mm (1 mm decrease since 0:00 on September 9) T.P.+ 2,895 mm (17 mm increase since 0:00 on September 9)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.