

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 11,)**

Water Level of the accumulated water (at 0:00 on September 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 907 mm (1 mm decrease since 0:00 on September 10)	T.P.+ 751 mm (30 mm decrease since 0:00 on September 10)	T.P.+ 891 mm (22 mm decrease since 0:00 on September 10)
	Water level of Reactor Building	T.P.+ 926 mm (11 mm decrease since 0:00 on September 10)	T.P.+ 966 mm (2 mm decrease since 0:00 on September 10)	T.P.+ 784 mm (26 mm decrease since 0:00 on September 10)	T.P.+ 778 mm (1 mm decrease since 0:00 on September 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 489 mm (29 mm increase since 0:00 on September 10) T.P.+ 663 mm (No change since 0:00 on September 10) T.P.+ 2,912 mm (17 mm increase since 0:00 on September 10)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.