

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 15,)**

Water Level of the accumulated water (at 0:00 on September 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 905 mm (1 mm decrease since 0:00 on September 14)	T.P.+ 720 mm (20 mm decrease since 0:00 on September 14)	T.P.+ 890 mm (2 mm decrease since 0:00 on September 14)
	Water level of Reactor Building	T.P.+ 949 mm (13 mm increase since 0:00 on September 14)	T.P.+ 970 mm (33 mm increase since 0:00 on September 14)	T.P.+ 765 mm (3 mm decrease since 0:00 on September 14)	T.P.+ 774 mm (No change since 0:00 on September 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 601 mm (9 mm decrease since 0:00 on September 14) T.P.+ 692 mm (33 mm increase since 0:00 on September 14) T.P.+ 3,031 mm (45 mm increase since 0:00 on September 14)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.