

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 17,)**

Water Level of the accumulated water (at 0:00 on September 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 907 mm (2 mm increase since 0:00 on September 16)	T.P.+ 731 mm (14 mm increase since 0:00 on September 16)	T.P.+ 895 mm (3 mm increase since 0:00 on September 16)
	Water level of Reactor Building	T.P.+ 952 mm (5 mm increase since 0:00 on September 16)	T.P.+ 970 mm (5 mm increase since 0:00 on September 16)	T.P.+ 763 mm (17 mm increase since 0:00 on September 16)	T.P.+ 773 mm (No change since 0:00 on September 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 368 mm (99 mm decrease since 0:00 on September 16) T.P.+ 748 mm (No change since 0:00 on September 16) T.P.+ 2,816 mm (261 mm decrease since 0:00 on September 16)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.