

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on September 20,)**

Water Level of the accumulated water (at 0:00 on September 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 916 mm (4 mm increase since 0:00 on September 19)	T.P.+ 756 mm (11 mm decrease since 0:00 on September 19)	T.P.+ 889 mm (6 mm decrease since 0:00 on September 19)
	Water level of Reactor Building	T.P.+ 954 mm (9 mm increase since 0:00 on September 19)	T.P.+ 954 mm (19 mm increase since 0:00 on September 19)	T.P.+ 800 mm (4 mm increase since 0:00 on September 19)	T.P.+ 819 mm (46 mm increase since 0:00 on September 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ 249 mm (64 mm increase since 0:00 on September 19) T.P.+ 788 mm (39 mm increase since 0:00 on September 19) T.P.+ 2,945 mm (44 mm increase since 0:00 on September 19)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.