

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 4,)**

Water Level of the accumulated water (at 0:00 on October 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 917 mm (1 mm increase since 0:00 on October 3)	T.P.+ 776 mm (10 mm increase since 0:00 on October 3)	T.P.+ 895 mm (7 mm increase since 0:00 on October 3)
	Water level of Reactor Building	T.P.+ 952 mm (No change since 0:00 on October 3)	T.P.+ 966 mm (2 mm decrease since 0:00 on October 3)	T.P.+ 807 mm (11 mm increase since 0:00 on October 3)	T.P.+ 809 mm (No change since 0:00 on October 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -288 mm (55 mm increase since 0:00 on October 3) T.P.+ 876 mm (No change since 0:00 on October 3) T.P.+ 2,821 mm (24 mm increase since 0:00 on October 3)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.