

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 0:00 on October 7,)**

Water Level of the accumulated water (at 0:00 on October 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Turbine Building	- Removal completed on March, 2017	T.P.+ 916 mm (No change since 0:00 on October 6)	T.P.+ 792 mm (1 mm decrease since 0:00 on October 6)	T.P.+ 908 mm (6 mm increase since 0:00 on October 6)
	Water level of Reactor Building	T.P.+ 953 mm (13 mm increase since 0:00 on October 6)	T.P.+ 963 mm (14 mm increase since 0:00 on October 6)	T.P.+ 826 mm (No change since 0:00 on October 6)	T.P.+ 809 mm (No change since 0:00 on October 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	T.P.+ -389 mm (82 mm decrease since 0:00 on October 6) T.P.+ 906 mm (No change since 0:00 on October 6) T.P.+ 2,907 mm (31 mm increase since 0:00 on October 6)		
Notes					

※ For quick publication of the data of water level, values are provided as reference values.